

**ATTACHMENT 1: BACKFLOW DEVICE REQUIREMENTS**

<b>APPLICATION</b>	<b>TYPE OF ASSEMBLY</b>
Auto Sales, Painting, Repair, Radiator work	RP
Auxiliary Water Supply (Contaminated Wells, etc.)	RP
Barber Shops	RP
Blood Banks	RP
Boiler Systems (any)	RP
Buildings with Booster Systems	RP
Buildings with 3 or more Stories or with fixtures 30 feet above the service	RP
Buildings with Sewage Ejectors	RP
Buildings with Storage Tanks	RP
Homes with Sewage Lift Stations	RP
Car Wash	RP
Camp Grounds / Trailer Parks	RP
Cement, concrete, Sand & Gravel Plants	RP
Chemical Storage or Processing Facilities	RP
Dairy or Cold Storage	RP
Film Processing	RP
Fire Systems - Business/Residential (sprinklers with or without hydrants or private hydrants)	DC w/Det.Ck.
Fire Systems - w/Sprinkler in Hazardous Locations	RP
Gas Stations	RP
Gray Water System	RP
Heating & Air Conditioning (Using Water)	RP
Hospital or Medical Facility (any) Convalescent or Long Term Care	RP
Irrigation Systems	RP
Irrigation System w/Chemical Feed	RP
Laboratories (Commercial or Research)	RP
Laundry or Dry Cleaner	RP
Manufacturing or Processing (with Toxic Chemicals)	RP
Medical or Dental Facility (any)	RP
Mobile Home Park	DC w/Det. Ck./RP
Ornamental Pools, Ponds or Fountains	RP
Painting Auto Shops	RP
Printing Shops	RP
Radiator Shops (all)	RP
Radioactive Materials	RP
Restaurant	RP
Restricted or Classified Facilities	RP
Schools	RP
Sewage or Storm Drain Facilities	RP

APPLICATION	TYPE OF ASSEMBLY
Steam Cleaning Equipment (any type)	RP
Steam Generation	RP
Swimming Pools (Public and Commercial)	RP
Tank Trucks or Spray Rigs	RP
Veterinary Clinics	RP
Warehousing & Storage	RP
KEY: RP = Reduced Pressure DC w/Det. Ck. = Double Check w/Detector Check	